

Danish Indoor Climate Labelling

Certificate no. 147



Danish Indoor Climate Labelling hereby certifies that the product group:

Outrup Windows and Doors

Outrup Vinduer og Døre A/S

Outrupstræde 31

DK-7900 Nykøbing Mors

has been approved and awarded a labelling license

The labelling license is valid through:

19 April 2026

Danish Indoor Climate Labelling

This certificate is subject to annual renewal according to the procedures of Danish Indoor Climate Labelling. Danish Indoor Climate Labelling may withdraw the rights to use this certificate in case the manufacturer does not meet the requirements.

Danish Indoor Climate Labelling

Certificate no. 147

Labelling license holder:

Outrup Vinduer og Døre A/S

Outrupstræde 31

DK-7900 Nykøbing Mors

Denmark

Product group:

Testing and labelling criteria

Date of first issue of license

Tested product(s)

Outrup Windows and Doors

General labelling criteria, 6th edition, 2018

Windows and exterior doors, 4th edition, 2018

4 April 2020

Door element impregnated according to system 4

Evaluation of product group

EMISSION CLASS 1

The labelling license covers products considered to be identical with the tested product regarding emission and particle characteristics as specified by the labelling criteria. For a full list of products covered by the labelling license, see Appendix.

The emission and particle classes were determined based on the following measured values:

Measured values after 28 days		
TVOC ₂₈	< 0.005	mg/m ³
Formaldehyde ₂₈	< 0.003	mg/m ³

Sensory evaluation	
Time-value	10 days

Labelling license basis

The tested product(s) shows compliance with the DICL criteria for the present product group:

Emission measured after 3 days			
TVOC	≤	10	mg/m ³
EU CARC 1A and 1B	≤	0.01	mg/m ³
Emission measured after 28 days			
Sum of TVOC and SVOC with LCI	≤	1.0	mg/m ³
EU CARC 1A and 1B	≤	0.001	mg/m ³
R-value	≤	1	
Sensory evaluation			
Time-value	≤	30	days

Emission Class 1	TVOC ₂₈	≤	0.5	mg/m ³
	Formaldehyde ₂₈	≤	0.01	mg/m ³
Emission Class 2	TVOC ₂₈	≤	1.0	mg/m ³
	Formaldehyde ₂₈	≤	0.06	mg/m ³
Emission Class 3	TVOC ₂₈	≤	1.0	mg/m ³
	Formaldehyde ₂₈	≤	0.1	mg/m ³

Product information requirements

The holder of the labelling license is required to present the following product information on demand in order to avoid any adverse effects of the product on the indoor air quality in practice: product specifications, guidelines for transport, storage, assembly, cleaning and maintenance.

In the event of any discrepancies in the text arising from translation, the Danish text shall prevail.